

April 2, 2021
Patriot Beverages, LLC WWTP
MA0004936-1

Ms. Nam Nguyen
U.S. EPA, Water Enforcement
OES4-SMR
5 Post Office Square, Suite 100
Boston, MA 02109-3912

Dear Ms. Nguyen:

Please find attached the Monthly Operation and Maintenance Report for March 2021.

The March 23rd Composite sample BOD analysis result was 66 mg/l. All other analysis were well within permit limits as usual. There were no operational indications that would have caused this result. I believe I must have made a sample collection error on March 24th. We did not receive the results until the afternoon of April 1st. A 24 hours composite sample was collected today and submitted to our contract lab for BOD analysis.

The WWTP is receiving off-site wastewater, daily, Monday through Saturday from the EPIC and CPF facilities in Ayer, Ma.

If you have any questions, please contact James Drapeau at (978) 339-5905 or e-mail at jdrapeau@cpf-nehf.com.

Sincerely,



James Drapeau
Chief Wastewater Operator
CPF Inc.

Attachment: 001-A Discharge Monitoring Report for March 2021 submitted by NetDMR
MA DEP Monthly Operations and Maintenance Report for March 2021 submitted by NetDMR
Off-Site Wastewater received spreadsheet for March 2021 submitted by NetDMR